

# General Environmental Incident Summary

**Incident:** 3671      **Date/Time Notice:** 2/27/2015      1300      **DEM Incident No:**  
**Responsible Party:** Farstad Oil  
**Date Incident:** 2/27/2015      **Time Incident:** 1130      **Duration:** 10 minutes  
**County:** Williams      **Twp:** 153      **Rng:** 102      **Sec:** 10      **Qtr:** SE SW  
**Lat:** 48.08491      **Long:** -103.78910      **Method:** Navigation quality GPS  
**Location Description:** Judson Compressor Station  
4614Hwy 1804Williston  
**Submitted By:** Kim Rudningen      **Affiliation:** ONEOK  
**Address:** 2700 Lincoln Ave SE  
**City:** Sidney      **State:** MT      **Zip:** 59270

## Received By:

**Contact Person:** Dallas Varty  
Minot  
Minot, ND

**Distance Nearest Occupied Building:** 0.25 Miles      **Release Contained:** Yes

**Type of Incident:** Tank Overflow

**Description of Released Contaminant:** lube oil

**Volume Spilled:** 20.00 gallons      **Ag Related:** No

**EPA Extremely Hazardous Substance:** No      **Reported to NRC:** No

## Cause of Incident:

: Farstad Oil was filling the lube oil tank located inside the compressor building at Judson and failed to turn off the pump immediately when the tank was full. This resulted in approximately 20 gallons of lube oil overrunning the tank onto the ground below the tank as well as onto a cabinet and some insulation adjacent to the tank location.

## Risk Evaluation:

there were no immediate risks associated with this release

**# of Fatalities:**      **# of Injuries:**      **Affected Medium:** 03 - soil

## Potential Environmental Impacts:

there are no expected environmental impacts from this release as it was contained within a small area inside the compressor building

## Action Taken or Planned:

Absorbent pads were placed over spill to absorb free standing oil. A crew was onsite to clean up impacted soil and debris.

**Wastes Disposal Location:** Impacted soil will be removed to a covered container until it can be disposed of in a certified landfill.

## Agencies Involved:

### ***Updates***

---

***Date:*** 2/27/2015

***Status:*** Reviewed; No Followup Required

***Staff:*** Roberts, Kris

***Updated Volume:***

***Notes:***

Small quantity release at a compressor station inside a building. No on-site followup is necessary.